REPORT OF DRILLED WELL

Doyle J Ponder — 193 — Rt 10 Box 337A, Cullman, Ala. 35055 — 24 ...
DRILLING CONTRACTOR — License Number — Address — Zip Code — Date

John Baker — Rt 3, Hanceville, Ala. 35077
PROPERTY OWNER — Address (mailing) — Zip Code

WELL LOCATION — Cullman — 23 — NE — 12s — 2W
County — Section — ¼ Section — Township — Range ---or:

I65 & 91 Exit NE o/a 4 miles t left go about 1 mile
Distance and direction from nearest town, community, road junction or other reference point

WELL WILL BE USED FOR: [X] Private supply [ ] Public supply [ ] Industrial supply [ ] Test well [ ] Irrigation Other:

6" Diameter of well — 150 Estimated depth

26 Jan 1978 Estimated starting date — Drilling method: (check) X Cable tool, Rotary, Jetted, Bored — Other:

Doyle J. Ponder
SIGNATURE of Drilling Contractor

Completion Date 17 Feb 1978

Total Depth 340

Interval	Description of cuttings	Interval	Description of cuttings
8'	clay		
17a'	Blue Shell		
14a	Grey Sand Rock		
20'	Shell		
2'	coal		

Completion date: report depths below ground level

Pump
Type: ☐ Turb. ☐ Subm. ☐ Jet ☐ Cyl:; Other:
Intake depth ____ H.P. ____ Yield ____ gpm

Capacity
Tested by: ☐ pumping ☐ air lift ☑ bailer ☐ none
Measured Static Water Level ____ ft.
Measured pumping level No Water ft. after ____ hrs. pumping 1 PINT P.M. gpm
Development time prior to testing ____ hrs.

Finish
☐ Open hole ☐ Screened ☐ Slotted pipe ☐ Gravel pk.
Interval(s) screened: ____ to ____ ft
____ to ____ ; ____ to ____ ft
Packer(s) set at ____ and ____ ft
Screen: diam. ____ ; Size openings ____

Casing

Interval cased	Diam. (inches)	*Type pipe	*Type couplings	Interval grouted
21	6"	PVC		Yes

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)

Other:

*Pipe: Black; PVC; Galv.; Other:

Quality
Water analysis obtained? (check) ☐ No ☐ Bacteriological ☐ Chemical

Analysis by: ☐ Ala Geol. Surv. ☐ Ala Health Dept. ☐ U.S. Geol. Surv. ☐ Private lab.

Signed:

RECEIVED
FEB 22 8 26 AM '78

*For deeper well please attach continuation sheet.

REPORT OF DRILLED WELL

Y

HT SPARKS 208 RT 2 BOX 40 HOLLYPOND AL 35083 4-10-90

DRILLING CONTRACTOR | License Number | Address | Zip Code | Date

FRED HELMS HANCEVILLE

PROPERTY OWNER | Address (mailing) | Zip Code

GARDENCITY CULLMAN

WELL LOCATION | County | Section | ¼ Section | Township | Range ---or:

1 MILE FROM GARDEN CITY EACT

Distance and direction from nearest town, community, road junction or other reference point

WELL WILL BE USED FOR: [✓] Private supply [ ] Public supply [ ] Industrial supply [ ] Test well [ ] Irrigation Other: _____

4-10-90 Estimated starting date

Drilling method: (check) Cable tool Rotary Jetted Bored Other: _____

6 Diameter of well

150 Estimated depth

H T Sparks

SIGNATURE of Drilling Contractor

Total Depth 140

Completion Date 4-20-90

Interval	Description of cuttings	Interval	Description of cuttings
	20 dirt		
	100 ft sandpack		
	20 ft shell		

Completion date: report depths below ground level

Pump
Type: [ ] Turb. [ ] Subm. [ ] Jet [ ] Cyl.; Other: _____
Intake depth _____ H.P. _____ Yield _____ gpm

Capacity
Tested by: [ ] pumping [ ] air lift [■] bailer [ ] none
Measured Static Water Level 60 ft.
Measured pumping level 80 ft. after
2 hrs. pumping 30 gpm
Development time prior to testing _____ hrs.

Finish
[ ] Open hole [ ] Screened [ ] Slotted pipe [ ] Gravel pk.
Interval(s) screened: _____ to _____ ft;
_____ to _____ ; _____ to _____ ft.
Packer(s) set at _____ and _____ ft.
Screen: diam. _____ ; Size openings _____

Casing

Interval cased	Diam. (inches)	*Type pipe	*Type couplings	Interval grouted
20 ft	6			

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)
Other: _____
*Pipe: Black; (PVC) Galv.; Other: _____

Quality
Water analysis obtained? (check) [ ] No [ ] Bacteriological [ ] Chemical
Analysis by: [ ] Ala Geol. Surv. [ ] U.S. Geol. Surv. [ ] Ala Health Dept. [ ] Private lab.
Signed:

*For deeper well please attach continuation sheet.

ADEM Form 60 1/83

Y

REPORT OF DRILLED WELL

H T SPARKS 208 RT 2 BOX 40 HOLLYPOND AL 35083 5-2-90

DRILLING CONTRACTOR | License Number | Address | Zip Code | Date

W H HILL HANEVILLE

PROPERTY OWNER | Address (mailing) | Zip Code

GARDEN CITY CULLMAN

WELL LOCATION | County | Section | ¼ Section | Township | Range ---or:

1 MILE EAST OF GARDEN CITY

Distance and direction from nearest town, community, road junction or other reference point

WELL WILL BE USED FOR: [✓] Private supply [ ] Public supply [ ] Industrial supply [ ] Test well [ ] Irrigation Other: _____

5-2-90 Estimated starting date

Drilling method: (check) (Cable tool) Rotary Jetted Bored Other: _____

6 Diameter of well

100 Estimated depth

H T Sparks

SIGNATURE of Drilling Contractor

Total Depth _____ Completion Date 5-10-90

Interval	Description of cuttings	Interval	Description of cuttings
	30 ft clay		
	40 ft sand rock		
	30 ft shale		

Completion date: report depths below ground level

Pump

Type: [ ] Turb. [ ] Subm. [ ] Jet [ ] Cyl.; Other: _____

Intake depth _____ H.P. _____ Yield _____ gpm

Capacity

Tested by: [ ] pumping [ ] air lift [■] bailer [ ] none

Measured Static Water Level 60 ft.

Measured pumping level 50 ft. after 3 hrs. pumping 30 gpm

Development time prior to testing _____ hrs.

Finish

[ ] Open hole [ ] Screened [ ] Slotted pipe [ ] Gravel pk.

Interval(s) screened: _____ to _____ ft; _____ to _____ ; _____ to _____ ft.

Packer(s) set at _____ and _____ ft.

Screen: diam. _____ ; Size openings _____

Casing

Interval cased	Diam. (inches)	*Type pipe	*Type couplings	Interval grouted
20 ft				

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)

Other: _____

*Pipe: Black; PVC; Galv.; Other: _____

Quality

Water analysis obtained? (check) [ ] No [ ] Bacteriological [ ] Chemical

Analysis by: [ ] Ala Geol. Surv. [ ] U.S. Geol. Surv. [ ] Ala Health Dept. [ ] Private lab.

Signed:

*For deeper well please attach continuation sheet.

ADEM Form 60 1/83

Y

NOTIFICATION OF INTENT TO DRILL A WATER WELL AND CERTIFICATION OF COMPLETION

Walker Drilling Service 563 PO Box 1564 Jasper Al 35502 9/7-06

DRILLING CONTRACTOR | License Number | Address | Zip Code | Date

Robert Coil Hancevilla Al.

PROPERTY OWNER | Address (mailing) | Zip Code

Cullman 12S 2W 6 NW/SE

WELL LOCATION | County | Township | Range | Section | 1/4 Section

I65, Exit 291 (Hwy 91) 6 miles to co Rd. 507, Right on private Drive 90 1/4 mile

Distance and direction from nearest town, community, road junction or other reference point

WELL TO BE USED FOR: ☑ Private supply ☐ Public supply ☐ Industrial supply ☐ Test well ☐ Monitoring well ☐ Irrigation Other: _____

LOCATION OF WELL: Latitude N34°12.936' Longitude W086°44.636' Diameter of well 5 1/4" Estimated depth 200'

9-7-06 Estimated starting date

Drilling Method: ☐ Cable tool ☑ Rotary ☐ Jetted ☐ Bored ☐ Other: _____

Bryan K Brown
SIGNATURE of Drilling Contractor

Total Depth 120' Completion Date 9/8/06

Interval	Description of cuttings
0	Weath Shale
16	Med S.S.
20	Shale w/ SS. Stks.
35	Med SS w/ shale stks.
50	X H SS
86	Water 20 GPM
120	T.D.

Completion date: report depths below ground level

Pump
Type: ☐ Turb. ☐ Subm. ☐ Jet ☐ Cyl Other _____
Intake depth _____ H.P. _____ Yield _____ gpm

Capacity
Tested by: ☐ pumping ☐ air lift ☐ bailer ☐ none
Measured Static Water Level _____ ft.
Measured pumping level _____ ft. after _____ hrs. pumping _____ gpm
Development time prior to testing _____ hrs.

Finish
☑ Open hole ☐ Screened ☐ Slotted pipe ☐ Gravel pk.
Inervals(s) screened: _____ to _____ ft; _____ to _____; _____ to _____ ft.
Packer(s) set at _____ and _____ ft.
Screen: diam. _____; Size openings _____

Casing

Interval cased	Diam. (Inches)	*Type pipe	*Type couplings	Interval grouted
0-20	6"	PVC		20

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)
Other: _____
*Pipe: Black; PCV; Galv.; Other: _____

Quality
Water analysis obtained? (check) ☐ No ☐ Bacteriological ☐ Chemical
Analysis by: ☐ Ala Geol. Surv. ☐ U.S. Geol. Surv. ☐ Ala Health Dept. ☐ Private lab.

Signed Certification:

*For deeper well please attach continuation sheet.

Send WHITE copy to:
ALABAMA GEOLOGICAL SURVEY
P.O. BOX 869999
TUSCALOOSA, AL 35486

Send YELLOW and PINK copies to:
ADEM DRINKING WATER BRANCH
P.O. BOX 301463
MONTGOMERY, AL 36130-1463

Retain GOLD copy for your Records

ADEM FORM 60 5/02

Y

NOTIFICATION OF INTENT TO DRILL A WATER WELL AND CERTIFICATION OF COMPLETION

DRILLING CONTRACTOR	License Number	Address	Zip Code	Date
Greg Sparks	561	710 Co. Rd. 1678 Cullman, AL	35058	5-20-10

PROPERTY OWNER	Address (mailing)	Zip Code
Phillip Wright	2488 Co. Rd. 616 Hanceville, AL	35077

WELL LOCATION	County	Township	Range	Section	1/4 Section
	Cullman	T12S	R2W		

Distance and direction from nearest town, community, road junction or other reference point

WELL TO BE USED FOR: ☒ Private supply ☐ Public supply ☐ Industrial supply ☐ Test well ☐ Monitoring well ☐ Irrigation Other: _____

LOCATION OF WELL: Latitude 34° 0.545N Longitude 86° 44.300W Diameter of well 6" Estimated depth 150'

Estimated starting date 5-25-10

Drilling Method: ☐ Cable tool ☒ Rotary ☐ Jetted ☐ Bored ☐ Other: _____

SIGNATURE of Drilling Contractor: Greg Sparks

Total Depth 200' Completion Date 5-24-10

Interval	Description of cuttings
0-25	clay
25-200	sandrock
	1 gpm

Pump
Type: ☐ Turb. ☒ Subm. ☐ Jet ☐ Cyl Other _____
Intake depth 190 H.P. 1 Yield 10 gpm

Capacity
Tested by: ☐ pumping ☒ air lift ☐ bailer ☐ none
Measured Static Water Level 30 ft.
Measured pumping level _____ ft. after _____ hrs. pumping _____ gpm
Development time prior to testing _____ hrs.

Finish
☐ Open hole ☐ Screened ☐ Slotted pipe ☐ Gravel pk.
Interval(s) screened: _____ to _____ ft; _____ to _____; _____ to _____ ft.
Packer(s) set at _____ and _____ ft.
Screen: diam. _____ ; Size openings _____

Casing

Interval cased	Diam. (inches)	*Type pipe	*Type couplings	Interval grouted
30'	6	PVC		30'

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)
Other: _____
*Pipe: Black; PCV; Galv.; Other: _____

Quality
Water analysis obtained? (check) ☒ No ☐ Bacteriological ☐ Chemical
Analysis by: ☐ Ala Geol. Surv. ☐ U.S. Geol. Surv. ☐ Ala Health Dept. ☐ Private lab.

Signed Certification: Greg Sparks

*For deeper well please attach continuation sheet.

Send WHITE copy to:
ALABAMA GEOLOGICAL SURVEY
P.O. BOX 869999
TUSCALOOSA, AL 35486

Send YELLOW and PINK copies to:
ADEM DRINKING WATER BRANCH
P.O. BOX 301463
MONTGOMERY, AL 36130-1463

Retain GOLD copy for your Records

ADEM FORM 60 5/02