REPORT OF DRILLED WELL

DRILLING CONTRACTOR	License Number	Address	Zip Code	Date
Fayfosh Well Ser.	400	194 Depot Rd	Luverne AL	

PROPERTY OWNER	Address (mailing)	Zip Code
Marion W. Cearley	Rt Box 504 Vinegar Bend Al.	36584

WELL LOCATION County	Section	¼ Section	Township	Range ---or:
Mobile Co	NW	30	T 2 N	R 4 W R 4 W

Distance and direction from nearest town, community, road junction or other reference point

WELL WILL BE USED FOR: ☑ Private supply ☐ Public supply ☐ Industrial supply ☐ Test well ☐ Irrigation Other: _____

4/20/95 Estimated starting date

Drilling method: (check) Cable tool, Rotary, ~~Jetted~~, Bored

Other: _____

4" Diameter of well

100' Estimated depth

Robert Zimmerman
SIGNATURE of Drilling Contractor

Total Depth 138'

Completion Date 4/25/95

Interval	Description of cuttings	Interval	Description of cuttings
0-5	top Soil		
5-20	Red Sand		
20-40	Clay		
40-60	Stratified Sand & Clay		
60-120	Clay (Sandy)		
120-138	Fine to med Sand		

Completion date: report depths below ground level

Pump
Type: ☐ Turb. ☑ Subm. ☐ Jet ☐ Cyl.; Other: _____
Intake depth 120' H.P. 3/4 Yield 20 gpm

Capacity
Tested by: ☐ pumping ☑ air lift ☐ bailer ☐ none
Measured Static Water Level 85 ft.
Measured pumping level 85 ft. after 1/2 hrs. pumping _____ gpm
Development time prior to testing 1/2 hrs.

Finish
☐ Open hole ☑ Screened ☐ Slotted pipe ☐ Gravel pk.
Interval(s) screened: 124 to 138 ft; _____ to _____; _____ to _____ ft.
Packer(s) set at none and _____ ft.
Screen: diam. 4" ; Size openings #8

Casing

Interval cased	Diam. (Inches)	*Type pipe	*Type couplings	Interval grouted
0-128	4"	PVC	W	Top 20

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)
Other: Wrapped w/ Black Screen
*Pipe: Black, PVC, Galv.; Other: _____

Quality
Water analysis obtained? (check) ☐ No ☐ Bacteriological ☐ Chemical
Analysis by: ☐ Ala Geol. Surv. ☐ U.S. Geol. Surv. ☐ Ala Health Dept. ☐ Private lab.
Signed:

*For deeper well please attach continuation sheet.

ADEM Form 60 1/83

E

NOTIFICATION OF INTENT TO DRILL A WATER WELL AND CERTIFICATION OF COMPLETION

DRILLING CONTRACTOR	License Number	Address	Zip Code	Date
Howard Drilling Co.	592	169 M. Fry Sogle Ln	Lucedale MS 39452	(5-22)

PROPERTY OWNER	Address (mailing)	Zip Code
Glen Blankenship	185 Hideaway Road Camden AL 36726	36726

WELL LOCATION	County	Township	Range	Section	1/4 Section
	Mobile	T2N	R4W	30	

Distance and direction from nearest town, community, road junction or other reference point: 3/4 mile past MS/AL State Line on HWY 96

WELL TO BE USED FOR: ☒ Private supply ☐ Public supply ☐ Industrial supply ☐ Test well ☐ Monitoring well ☐ Irrigation Other: N/A

LOCATION OF WELL: Latitude 31° 06.322 Longitude 88° 25.318 Diameter of well 4" Estimated depth 100 ft

Estimated starting date 5-25-03

Drilling Method: ☒ Cable tool ☐ Rotary ☐ Jetted ☐ Bored ☐ Other: N/A

SIGNATURE of Drilling Contractor

Total Depth 155 ft Completion Date 5-27-03

Interval	Description of cuttings
0-2	Topsand
2-18	Sand, fine to med
18-21	Clay
21-27	Sand, fine
27-33	Sand, fine to med
33-52	Clay
52-56	Sand, fine to med
56-65	Clay
65-78	Sand, fine
78-89	Clay
89-93	Sand, fine to med
93-108	Clay
108-112	Sand, fine
112-118	Sand, fine to med
118-121	Clay
121-136	Sand, med
136-139	Clay
139-155	Sand, med

Completion date: report depths below ground level

Pump: Type: ☐ Turb. ☒ Subm. ☐ Jet ☐ Cyl Other ____ Intake depth 150 H.P. 1 Yield 17 gpm

Capacity: Tested by: ☐ pumping ☒ air lift ☐ bailer ☐ none; Measured Static Water Level 103 ft; Measured pumping level 118 ft. after 1 hrs. pumping 17 gpm; Development time prior to testing .75 hrs.

Finish: ☐ Open hole ☒ Screened ☐ Slotted pipe ☐ Gravel pk.; Inerval(s) screened: 145 to 155 ft; ____ to ____; ____ to ____ ft.; Packer(s) set at ____ and ____ ft.; Screen: diam. 4; Size openings .008

Casing:

Interval cased	Diam. (inches)	*Type pipe	*Type couplings	Interval grouted
0-145	4	PVC S40	SW	0-18

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)

Other: ____

*Pipe: Black; PCV; Galv.; Other: ____

Quality: Water analysis obtained? (check) ☒ No ☐ Bacteriological ☐ Chemical

Analysis by: ☐ Ala Geol. Surv. ☐ U.S. Geol. Surv. ☐ Ala Health Dept. ☐ Private lab.

Signed Certification: 592

*For deeper well please attach continuation sheet.

Send WHITE copy to:
ALABAMA GEOLOGICAL SURVEY
P.O. BOX 869999
TUSCALOOSA, AL 35486

Send YELLOW and PINK copies to:
ADEM DRINKING WATER BRANCH
P.O. BOX 301463
MONTGOMERY, AL 36130-1463

Retain GOLD copy for your Records

ADEM FORM 60 5/02

E

NOTIFICATION OF INTENT TO DRILL A WATER WELL AND CERTIFICATION OF COMPLETION

DRILLING CONTRACTOR	License Number	Address	Zip Code	Date
Howard Drilling	593	169 M. Fryfogle	39452	

PROPERTY OWNER	Address (mailing)	Zip Code
Jason Blankinship	15979 Beveling Hwy Citronell Al	36522

WELL LOCATION	County	Township	Range	Section	1/4 Section
	Mobile	T2N	R4W	30	

10 W of Citronelle

Distance and direction from nearest town, community, road junction or other reference point

WELL TO BE USED FOR: ☑ Private supply ☐ Public supply ☐ Industrial supply ☐ Test well ☐ Monitoring well ☐ Irrigation Other: _____

LOCATION OF WELL: Latitude 31°06 21N Longitude 088°25' 38W Diameter of well 4" Estimated depth 80'

Estimated starting date _____

Drilling Method: ☐ Cable tool ☑ Rotary ☐ Jetted ☐ Bored ☐ Other: _____

[signature]
SIGNATURE of Drilling Contractor

Total Depth 60'

Completion Date 4-23-03

Interval	Description of cuttings
0 - 3	top sand
3 - 12	Med sand
12 - 35	Clay
35 - 60	sand

Completion date: report depths below ground level

Pump
Type: ☐ Turb. ☑ Subm. ☐ Jet ☐ Cyl Other _____
Intake depth 55 H.P. 1 Yield 30 gpm

Capacity
Tested by: ☑ pumping ☐ air lift ☐ bailer ☐ none
Measured Static Water Level 29 ft.
Measured pumping level 40 ft. after 1 hrs. pumping 30 gpm
Development time prior to testing 1 hr hrs.

Finish
☐ Open hole ☑ Screened ☐ Slotted pipe ☑ Gravel pk.
Inerval(s) screened: 50 to 60 ft; _____ to _____; _____ to _____ ft.
Packer(s) set at _____ and _____ ft.
Screen: diam. 4"; Size openings #10

Casing

Interval cased	Diam. (Inches)	*Type pipe	*Type couplings	Interval grouted
	4"	PVC40		

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)
Other: _____
*Pipe: Black; PCV; Galv.; Other: _____

Quality
Water analysis obtained? (check) ☑ No ☐ Bacteriological ☐ Chemical
Analysis by: ☐ Ala Geol. Surv. ☐ U.S. Geol. Surv. ☐ Ala Health Dept. ☐ Private lab.

Signed Certification:

*For deeper well please attach continuation sheet.

Send WHITE copy to:
ALABAMA GEOLOGICAL SURVEY
P.O. BOX 869999
TUSCALOOSA, AL 35486

Send YELLOW and PINK copies to:
ADEM DRINKING WATER BRANCH
P.O. BOX 301463
MONTGOMERY, AL 36130-1463

Retain GOLD copy for your Records

ADEM FORM 60 5/02