REPORT OF DRILLED WELL

II

Steve Powell — DRILLING CONTRACTOR
License Number
PO Box 249 — Address
Uriah — Address
36480 — Zip Code
11-15-96 — Date

Cary Silcox — PROPERTY OWNER
PO Box 940 — Address (mailing)
Frisco City AL — Address (mailing)
36445 — Zip Code

WELL LOCATION
Monroe — County
18 — Section
SW — ¼ Section
5N — Township
8E — Range ---or:

2 miles East of Hwy 84 on Old Stage Rd
Distance and direction from nearest town community, road junction or other reference point

WELL WILL BE USED FOR: [✓] Private supply [ ] Public supply [ ] Industrial supply [ ] Test well [ ] Irrigation Other: _____

11-10-96 — Estimated starting date

Drilling method: (check) Cable tool / [✓] Rotary / Jetted / Bored Other: _____

4" — Diameter of well

130 — Estimated depth

Steve Powell — SIGNATURE of Drilling Contractor

Total Depth 160

Completion Date 11-15-96

Interval	Description of cuttings	Interval	Description of cuttings
1-8	Top Soil		
8-19	Sand		
19-42	Gravel		
42-102	Clay		
102-122	Sand		
122-160	Gravel		

Completion date: report depths below ground level

Pump
Type: [ ] Turb. [✓] Subm. [ ] Jet [ ] Cyl.; Other: _____
Intake depth 100 H.P. 1 Yield 23 gpm

Capacity
Tested by: [✓] pumping [ ] air lift [ ] bailer [ ] none
Measured Static Water Level 85 ft.
Measured pumping level 87 ft. after 24 hrs. pumping 23 gpm
Development time prior to testing _____ hrs.

Finish
[ ] Open hole [✓] Screened [ ] Slotted pipe [ ] Gravel pk.
Interval(s) screened: 140 to 160 ft.
_____ to _____ ; _____ to _____ ft.
Packer(s) set at _____ and _____ ft.
Screen: diam. 4" ; Size openings .012

Casing

Interval cased	Diam. (Inches)	*Type pipe	*Type couplings	Interval grouted
140	4"	PVC		20

*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)
Other: _____
*Pipe: Black; PVC; Galv.; Other: _____

Quality
Water analysis obtained? (check) [✓] No [ ] Bacteriological [ ] Chemical
Analysis by: [ ] Ala Geol. Surv. [ ] U.S. Geol. Surv. [ ] Ala Health Dept. [ ] Private lab.
Signed: Steve Powell

*For deeper well please attach continuation sheet.

ADEM Form 60 1/83